



2024 WATER QUALITY REPORT



INTRODUCTION

The Village of Mount Prospect is dedicated to providing you with an adequate and dependable supply of safe drinking water. As part of this effort, we have prepared this **Consumer Confidence Report (CCR)**. This report will provide residents and businesses served by the Village-owned water distribution system with the information necessary to make prudent decisions about how they use tap water. **Please note, information in this CCR does not pertain to Illinois American Water Company water customers.** Illinois American Water Company will prepare and distribute a separate CCR for their water customers and they can be reached at 1-800-422-2782.

This report is a requirement of the 1996 Safe Drinking Water Act amendments. It summarizes where your water came from, what it was made of, and how it compared to the standards established by regulatory agencies. Information about water consumed during the reporting year will be made available in a CCR scheduled for distribution during the following year. CCRs will be published in July of each year.

Information in this report describes water consumed during the **2024** calendar year. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at 1-800-426-4791.

ADDITIONAL COPIES OF THIS REPORT WILL BE AVAILABLE AT:

- Public Works Facility, 1700 W. Central Road
- Mount Prospect Public Library, 10 S. Emerson Street
- Village Hall, 50 S. Emerson Street
- Community Connections Center, 1711 W. Algonquin Road

Village of Mount Prospect Public Works Department

1700 W. Central Road
Mount Prospect, IL 60056
(847) 870-5640

www.mountprospect.org/publicworks

  @MountProspectPW

WHERE DO WE GET OUR WATER?

Our water supply comes from Lake Michigan, one of the five Great Lakes. **The lake water is treated and purified at the Jardine Water Purification Plant by the City of Chicago, Department of Water Management (312-744-6635).** The finished drinking water is then pumped to the **Northwest Suburban Municipal Joint Action Water Agency (NSMJAWA)** reservoirs. NSMJAWA then pumps the water to Mount Prospect and six (6) other northwest suburban communities via large water transmission mains. Two of these mains terminate at three receiving structures in Mount Prospect. The structures are situated at various locations throughout the Village. Prior to receiving lake water, the Village pumped water from as many as 17 public deep wells located throughout the Village. The Village maintains only four (4) remaining wells for standby or emergency use. By area, Lake Michigan is the third largest of the Great Lakes and second largest by volume. Hydrologically, Lake Michigan is inseparable from Lake Huron. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive materials. It can also pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which may be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also come from gas stations, urban stormwater runoff, and septic systems; and
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Untreated lake water has the potential to contain these types of contaminants. However, it is important to realize that these materials can be found throughout nature to some degree. Their presence does not necessarily mean that there is a health risk associated with our source water. Rather, the most important factor to consider is how much of a particular contaminant can be found in our source water.

Fortunately, the quality of raw, untreated Lake Michigan water is good. This means that conventional treatment methods, such as disinfection with chlorine, coagulation, and sedimentation with sand filtration can be used effectively to produce large quantities of safe drinking water.

HAS AN ASSESSMENT BEEN MADE OF LAKE MICHIGAN WATER?

Yes. The Source Water Assessment for our water supply has been completed by the Illinois Environmental Protection Agency (IEPA). The IEPA considers all surface water sources of community water supply to be susceptible to potential pollution problems. The very nature of surface water allows contaminants to migrate into the intake with no protection only dilution. This is the reason for mandatory treatment for all surface water supplies in Illinois. Chicago's offshore intakes are located at a distance that shoreline impacts are not usually considered a factor on water quality. At certain times of the year, however, the potential for contamination exists due to wet-weather flows and river reversals. In addition, the placement of the crib structures may serve to attract waterfowl, gulls and terns that frequent the Great Lakes area, thereby concentrating fecal deposits at the intake and thus compromising the source water quality. Conversely, the shore intakes are highly susceptible to storm water runoff, marinas and shoreline point sources due to the influx of groundwater to the lake.

Further information regarding our source water assessment; please contact the City of Chicago, Department of Water Management at 1-312-744-4420 or the Northwest Suburban Municipal Joint Action Water Agency at 1-773-686-0077. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the IEPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

WHO DECIDES IF WATER IS SAFE TO DRINK?

In order to ensure that tap water is safe to drink; the United States Environmental Protection Agency (USEPA) and the IEPA prescribes regulations which limit the amount of certain contaminants in the water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

IS MOUNT PROSPECT'S DRINKING WATER SAFE?

Yes, it is. Last year, Mount Prospect complied with all the federal and state regulations pertaining to the storage and distribution of drinking water.

The table on Page 3 summarizes the tests that were performed to ensure compliance with water quality standards. Page 4 has additional tables and outlines the definitions associated with this information.

In addition to both the Village and the City of Chicago tests, the Village's water distributor, the Northwest Suburban Municipal Joint Action Water Agency (NSMJAWA) also performs a number of water quality tests. No violations were recorded.



ARE THERE ANY PROBLEMS WITH LEAD IN OUR WATER?

No. Village tests for lead and copper content indicate that there are no unhealthy levels of either contaminant in our drinking water.

Lead can cause serious health problems, especially for pregnant women and young Children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Mount Prospect is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested. Contact Water/Sewer Superintendent Casey Botterman with the Village of Mount Prospect Public Works at 847-870-5640. Information about lead in drinking water, testing methods, and steps you can take minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Presently, the Village tests for lead and copper content once every three (3) years. We collect samples from the taps of 30 private homes. In order to avoid corrective action, the samples at the 90th percentile must be less than the Maximum Contaminant Level (MCL) established for each contaminant. The table on page 3 summarizes the results of our last round of lead and copper testing, which we completed in 2023.

For a copy of the most recent lead tap sampling results please feel free to contact the Village of Mount Prospect Public Works Department at 847-870-5640. Or, if you prefer, send an e-mail message to cbotterman@mountprospect.org

The Village of Mount Prospect has inventoried all water services that our supplied by the Villages distribution system. Residents can access the Villages service line inventory through the below link. <https://mountprospectil.maps.arcgis.com/apps/webappviewer/index.html?id=ca4ad0a66bb74ba5acf9bc9ba0f486c9>

EN ESPAÑOL

La ciudad de Mount Prospect continua ofreciendo la mejor calidad de agua y servicios a nuestros clientes. Parte de estos servicios es proveer información acerca del estado presente y futuro del agua. En el folleto "Confianza al Consumido" se da suficiente información para que usted pueda tomar decisiones con respecto al suministro y al uso del agua. Este informe es un requisito de la enmendadura del "Safe Drinking Water Act" de 1996, administrada por las agencias "United States Environmental Protection Agency" (USEPA) y "Illinois Environmental Protection Agency" (IEPA). Si usted tiene alguna pregunta acerca de la calidad del agua, por favor llame al teléfono (847) 870-5640.



WHO CAN I TALK TO IF I HAVE QUESTIONS OR COMMENTS ABOUT THE VILLAGE-OWNED WATER SYSTEM?

If you have any questions about this report, or would like additional information about the Village-owned water system, please feel free to contact Water/Sewer Superintendent Casey Botterman at 847-870-5640. Or, if you prefer, send an e-mail message to cbotterman@mountprospect.org.

In addition, the Mayor and Board of Trustees of the Village of Mount Prospect hold regular board meetings on the first and third Tuesday of every month. These meetings commence at 7:00 PM in the Village Hall. The Village Hall is located at 50 South Emerson Street. Questions or comments about the Village-owned water system may be introduced at any of these meetings.

SUBSTANCE (UNITS) Agency	MCLG	MCL	AMOUNT	RANGE OF DETECTION	VIOLATION NOTED	DATE SAMPLED	TYPICAL SOURCE OF CONTAMINATION
REGULATED AND TESTED FOR IN THE VILLAGE-OWNED WATER DISTRIBUTION SYSTEM ¹							
Total Coliform Bacteria (TC) (%pos/ mo.) City of Chicago	0	5%	1.9	N/A	None		Naturally present in environment
Fecal Coliform (FC) and E. Coli (#pos/ mo.)	0	0	0	N/A	None		Naturally present in environment; Human and animal fecal waste
Total Trihalomethanes- TTHM (ppb)	N/A	80	56 (highest value)	18.3 - 80	None	2024	By-product of drinking water disinfection
Haloacetic Acids -HAA5 (ppb)	N/A	60	21 (highest value)	11.75 - 29	None	2024	By-product of drinking water disinfection
Chlorine (as Cl ₂) (ppm)	MRDLG= 4	MRDL=4	1.0 (highest value)	0.5 - 1.2	None	2024	Water additive used to control microbes
REGULATED AND TESTED FOR AT THE VILLAGE'S STANDBY EMERGENCY WELLS ^{1, 2}							
Arsenic (ppb)	0	10	0.532	0.187 - 0.532	None	2024	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production waste.
Barium (ppm)	2	2	0.0326	0.0238 - 0.0326	None	2024	Discharge from drilling wastes; discharge from metal refineries and erosion of natural deposits.
Fluoride (ppm)	4	4.0	1.83	0.95 - 1.83	None	2024	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Iron (ppm)	N/A	1.0	1.31	0.222 - 1.31	None	2024	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Manganese (ppb)	150	150	24.7	15.5 - 24.7	None	2024	This contaminant is not currently regulated by the USEPA. However the state regulates erosion of natural deposits.
Selenium (ppb)	50	50	1.75	0.362 - 1.75	None	2024	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge for mines.
Sodium (raw water) (ppm)	NA	NA	66700	31100 - 66700	None	2024	Erosion from naturally occurring deposits; used in water softener regeneration.
Zinc	5	5	0.0299	0.000874 - 0.0299	None	2024	This contaminant is not currently regulated by the USEPA. However, the state regulates. Naturally occurring; discharge from metal
Combined Radium (226/228) (pCi/L)	0	5	5.7	5.7 - 5.7	None	2024	Erosion of natural deposits
Gross Alpha (excluding radon and uranium)	0	15	13	13 - 13	None	2024	Erosion of natural deposits
Uranium (ug/l)	0	30	0.48425	0.48425 - 0.48425	None	2023	Erosion of natural deposits
Ethylbenzene	700	700	17.2	0 - 17.2	None	2024	Discharge from petroleum refineries.
Toluene	1	1	0.0037	0 - 0.0037	None	2024	Discharge from petroleum factories.
Xylenes	10	10	0.014	0 - 0.0594	None	2024	Discharge from Petroleum Factories; Discharge from chemical factories.

REGULATED AND TESTED FOR AT THE CUSTOMERS' TAP (SAMPLE OF 30 HOMES) ¹							
SUBSTANCE (UNITS) Agency	MCLG	ACTION LEVEL (AL)	90TH PERCENTILE	#SITES OVER AL	VIOLATION	DATE SAMPLED	TYPICAL SOURCE OF CONTAMINATION
Copper (ppm)	1.3	Action Level = 1.3 ppm	0.0531	0 exceeding AL	None	2023	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives
Lead (ppb)	0	Action Level = 15 ppb	2.82	0 exceeding AL	None	2023	Corrosion of household plumbing systems; Erosion of natural deposits

DEFINITIONS

AL - Action Level. The concentration of a contaminant that triggers treatment or other required actions by the water supply.

Avg – Average. Regulatory compliance with some MCLs is based on running annual average of monthly samples.

MCLG - Maximum Contaminant Level Goal. The level of a contaminant in drinking water below, which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL - Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology.

mg/l – milligrams per liter, see 'ppm'

MRDLG – Maximum Residual Disinfectant Level Goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MRDL – Maximum Residual Disinfectant Level. The highest level of a drinking water disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

NA - Not Applicable

ND - Not detectable at testing limits

NTU - Nephelometric Turbidity Unit, used to measure cloudiness in the drinking water.

pCi/L - Picocuries per liter, used to measure radioactivity.

ppb - Parts Per Billion (same as ug/l) or one ounce in 7,350,000 gallons of water

ppm - Parts Per Million (same as mg/l) or one ounce in 7,350 gallons of water

ppq – Parts per quadrillion or pictograms per liter

ppt – Parts per Trillion or nanograms per liter

TT - Treatment Technique. A required process intended to reduce the level of a contaminant in drinking water

#pos/ mo - This represents the number of positive samples per month

%pos/ mo - This represents the percentage of positive samples per month

%< 0.5 NTU - Percent of samples less than .5 NTU.

"Amount" column is an average of all sample result data collected during the CCR calendar year.

"Range of Detections" represents a range of individual sample results, from lowest to highest, taken during the CCR calendar year.

"Date of Sample" represents whether the sample was collected during the CCR calendar year or the last time IEPA required samples to be collected. If no date appears, then the sample was collected during the reporting year.

Turbidity - measurement of the cloudiness of the water caused by suspended particles. It is monitored because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Sodium - there is no MCL for sodium. However, individuals on a sodium restricted diet should consider consulting a physician about this level of sodium in the water.

VULNERABLE POPULATIONS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline at 1-800-426-4791.

IMPORTANT NOTE

In order to ensure that tap water is safe to drink, USEPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at 1-800-426-4791.

SUBSTANCE (UNITS) Agency	MCLG	MCL	AMOUNT	RANGE OF DETECTION	VIOLATION NOTED	DATE SAMPLED	TYPICAL SOURCE OF CONTAMINATION
REGULATED AND TESTED FOR BY THE CITY OF CHICAGO OR BY NSMJAWA ¹							
Total Trihalomethanes – TTHM (ppb) Highest Running Annual Average Computed NSMJAWA	NA	80	45	33 – 45.1	None	2024	By-product of drinking water disinfection
Haloacetic Acids - HAA5 (ppb) Highest Running Annual Average Computed NSMJAWA	NA	60	22	15.9 – 21.6	None	2024	By-product of drinking water disinfection
Chlorine (ppm) NSMJAWA	MRDLG = 4.0	MRDL= 4.0	1.4 (highest value)	1.18 – 1.66	None	2024	Water additive used to control microbes
Turbidity (NTU) Highest single measurement City of Chicago	NA	TT (limit: 1 NTU)	0.39 NTU	NA	NA		Soil runoff
Turbidity (%<0.3 NTU) Lowest monthly percent meeting limit. – City of Chicago	NA	TT (95%≤0.3NTU)	Lowest Monthly % 99.7%	99.7% - 100%	NA		Soil runoff
Barium (ppm) City of Chicago	2	2	0.0203	0.0198 – 0.0203	None		Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride (ppm) City of Chicago	4	4	0.76	0.67 – 0.76	None		Water additive that promotes strong teeth
Nitrate (as Nitrogen) (ppm) City of Chicago	10	10	0.39	0.36 – 0.39	None		Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Total Nitrate & Nitrite (as Nitrogen) (ppm)	10	10	0.39	0.36 – 0.39	None		Runoff from fertilizer use; leaching from septic tanks, sewage; Erosion of natural deposits
Sulfate (ppm) City of Chicago	NA	NA	28.2	25.3 – 28.2	None		Erosion of naturally occurring deposits
Sodium (ppm) City of Chicago	NA	NA	918	8.87 – 918	None		Erosion of naturally occurring deposits; Used as water softener
Combined Radium (226/228) (pCi/L)	0	5	0.95	0.83 - 0.95	None	2/04/2020	Decay of natural and man-made deposits
Gross Alpha excluding Radon and Uranium (pCi/L) City of Chicago	0	15	3.1	2.8 - 3.1	None	2/04/2020	Decay of natural and man-made deposits
Copper (ppm)	1.3	AL = 1.3	0.12 90th percentile	0 sites exceeding AL	None	2022	Corrosion of household plumbing system; Erosion of natural deposits; leaching from wood preservatives
Lead (ppb)	0	AL = 15	7.7 90th percentile	1 site exceeding AL	None	2022	Corrosion of household plumbing systems; Erosion of natural deposits
TOC (Total Organic Carbon) City of Chicago	The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set by IEPA.						
¹ If a date appears, the IEPA requires monitoring for this substance less than once per year because the concentrations do not frequently change. No date indicates monitoring was done during the current CCR reporting year. ² No water was pumped into the water distribution system from emergency standby wells during the reporting period.							
Cryptosporidium, Giardia and E.coli is monitored by the City of Chicago in its water quality program and in compliance with the Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR) Round 2. No Cryptosporidium or Giardia has been detected.							
REGULATED AND TESTED FOR BY THE VILLAGE'S BACKUP LAKE MICHIGAN WATER SOURCE - NORTHWEST WATER COMMISSION							
Chlorine	4	MRDL = 4.0	1	0.9 - 1	None	2024	Water Additive used to control Microbes
Haloacetic Acids (HAA5)	NA	60	16	13.79 - 15.82	None	2024	By-product of drinking water disinfection
Total Trihalomethane (TTHM)	NA	80	29	25.1 - 29.1	None	2024	By-product of drinking water disinfection

FIFTH UNREGULATED CONTAMINANT MONITORING RULE (UCMR5)

As required by UCMR 5, EPA'S latest monitoring cycle, The Village of Mount Prospect has completed monitoring of 25 perfluorinated & polyfluorinated alkyl substances, 4 perfluorinated alkyl acids, and lithium in its drinking for four quarters in 2024. None of the contaminates were detected in the Villages drinking water.

VIOLATION SUMMARY TABLE

Benzene, Ethylbenzene, Toluene, Xylenes (7/1/2024 – 9/30/2024) – We failed to test our drinking water for the contaminant during the period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated. The location for these tests is at one of the Villages Emergency Deep wells. **We have since taken the required samples as described in the last paragraph. The results showed we are meeting drinking water standards.**

- Benzene - Excess of the MCL over many years could experience anemia or a decrease in blood platelets, and mya have an increased risk of getting cancer.
- Ethylbenzene - Excess of the MCL over many years could experience problems with their liver or kidney.
- Toluene – Excess of the MCL over many years could have problems with their nervous system, kidneys or liver.
- Xylenes – Excess of the MCL over many years could experience damage to their nervous system.

Revised total Coliform (12/1/2024 – 12/31/2024) – The revised total coliform rule seeks to prevent waterborne diseases caused by E. coli. E. Coli are bacteria whose presence indicates that the water may be contaminated with human or animal waste. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea and headaches. We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated. We have since taken the required samples as described in the last paragraph. The results showed we are meeting drinking water standards.