

Parameter	MCL	Well 16	Well 11	Well 17	Well 5
Aluminum	50	ND	ND	ND	ND
Boron	600	914	362	324	896
Cadmium	5	ND	ND	ND	ND
Calcium	100,000	73,800	79,000	86,100	93,000
Chromium	100	ND	ND	ND	ND
Cobalt	4 millirems/yr	ND	ND	ND	ND
Hardness, Ca/Mg (As CaCO3)	250,000	247,000	285,000	297,000	320,000
Iron	300	489	1,380	486	563
Lithium		50.5	ND	ND	55.0
Magnesium		15,300	21,400	19,900	21,300
Phosphorus		ND	ND	ND	ND
Potassium		13,800	14,000	13,100	18,500
Silicon		4,310	3,980	4,060	3,860
Sodium		51,400	36,400	30,900	70,700
Strontium	4 millirems/yr	1,560	5,050	5,300	2,400
Titanium		ND	ND	ND	ND
Vanadium		ND	ND	ND	ND
Zinc	500	48	29.4	44.0	ND
Sulfur		-	-	-	49,300
Antimony	6.00	ND	ND	ND	ND
Arsenic	10.0	0.270	0.280	0.250	0.612
Barium	2,000	24.5	30.8	32.6	26.6
Beryllium	4.00	ND	ND	ND	ND
Copper	1,300	12.1	16.8	14.3	4.09
Lead	15.0	ND	ND	1.15	ND
Manganese	150	26.7	16.1	21.6	19.3
Molybdenum		0.852	0.845	0.698	0.547
Nickel	100	2.86	3.85	3.15	2.56
Selenium	50.0	0.811	0.452	0.393	1.8
Silver	100	ND	ND	ND	ND
Thallium	2.00	ND	ND	ND	ND
Alkalinity, Total(As CaCO3)		219	258	258	229
Alkalinity, phenolphthalein		219	259	257	243
Bromide		ND	0.26	ND	0.51
Chloride	250	42	15	21	96
Cyanide	0.20	ND	ND	ND	0.0027
Chemical Oxygen Demand		ND	ND	ND	ND
Color (Apparent)	15	-	-	-	58
Color (True)	15	ND	ND	ND	ND
Specific Conductivity		745	746	738	1,100
Fluoride	4.00	1.93	1.02	1.08	1.53
Mercury	2.00	ND	ND	ND	ND
Nitrogen, Ammonia (As N)		0.342	0.272	0.295	0.663

Nitrogen, Nitrite	1.0	ND	ND	ND	ND
Nitrate	10	ND	ND	ND	ND
NITRATE as N	3.0	ND	ND	ND	ND
Odor		1	1	1	1
Orthophosphate (As P)		ND	ND	ND	ND
Orthophosphate (As PO4)		ND	ND	ND	ND
Total Phosphorus(as PO4)		ND	0.09	0.075	ND
Phosphorus (As P)		ND	0.029	0.025	ND
Phosphate		ND	0.09	0.075	ND
Sulfate	250	94.6	104	91.2	131
Residue, Filterable		410	612	408	594
Total Organic Carbon DW		ND	ND	ND	ND
Percent Solids		-	-	-	0.132
Turbidity	5.49	4.11	11.1	2.27	8.15

Well Units	CDWM	CDWM Units
ug/L	144	ug/L
ug/L	23.8	ug/L
ug/L	<1	ug/L
ug/L	34,300	ug/L
ug/L	<1	ug/L
ug/L	<1	ug/L
ug/L	136,000	ug/L
ug/L	14.8	ug/L
ug/L	1.02	ug/L
ug/L	12,200	ug/L
ug/L	-	-
ug/L	1,470	ug/L
ug/L	865	ug/L
ug/L	8,990	ug/L
ug/L	107	ug/L
ug/L	2.63	ug/L
ug/L	<1	ug/L
ug/L	28.0	ug/L
ug/L	-	-
ug/L	<1	ug/L
ug/L	<1	ug/L
ug/L	19.3	ug/L
ug/L	<1	ug/L
ug/L	1.74	ug/L
ug/L	1.23	ug/L
ug/L	1.10	ug/L
ug/L	<1	ug/L
ug/L	1.64	ug/L
ug/L	<1	ug/L
ug/L	<1	ug/L
ug/L	<1	ug/L
as CaCO3, mg/L		as CaCO3, mg/L
as CaCO3, mg/L	0	as CaCO3, mg/L
mg/L	<0.25	mg/L
mg/L	15.2	mg/L
mg/L	<0.020	mg/L
mg/L	4.29	mg/L
APHA	<5	Apparent CU
APHA	-	-
UMHO/CM	303	uS/cm@25°C
mg/L	15.2	mg/L
ug/L	<0.25	mg/L
mg/L	<0.10	mg/L

- Below CDWM and Below MCL
- Below MCL and Above CDWM
- Above MCL and Above CDWM
- No MCL and Above CDWM
- No MCL and No Clear CDWM Dat
- No MCL and Below CDWM

mg/L	<0.25	mg/L
mg/L	-	-
mg/L	0.261	mg/L
T.O.N.	1	T.O.N.
mg/L	0.625	mg/L
mg/L	0.570	mg/L
mg/L	-	-
mg/L	-	-
mg/L	1.31	mg/L
mg/L	24.5	mg/L
mg/L	-	-
mg/L	1.66	mg/L
wt%	-	-
NTU	0.20	NTU

a